

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE
PAGE OF PAGES
1 3

2. AMENDMENT/MODIFICATION NO. 0002
3. EFFECTIVE DATE 11 June 03
4. REQUISITION/PURCHASE REQ. NO.
5. PROJECT NO. (If applicable)

6. ISSUED BY CODE N00173
7. ADMINISTERED BY (If other than Item 6) CODE
CONTRACTING OFFICER
NAVAL RESEARCH LABORATORY
4555 OVERLOOK AVENUE SW
WASHINGTON, DC 20375-5326
ATTN: CODE:3220.d1

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)
ALL OFFERORS
(X) 9A. AMENDMENT OF SOLICITATION NO. N00173-03-R-DL08
9B. DATED (SEE ITEM 11) 8 May 03
10A. MODIFICATION OF CONTRACT/ORDER NO.
10B. DATED (SEE ITEM 11)
CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

See Page 2.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
<i>(Signature of person authorized to sign)</i>		<i>(Signature of Contracting Officer)</i>	

The purpose of this amendment is to provide answers to questions from potential offerors, provide revised drawings (Exhibit A) and changes to Exhibit B, Specifications.

1. The following is in response to potential offeror's questions:

Question. Is a bid bond required? No reference in the instructions to one.

Answer. A bid bond is not required.

Question. We assume bids can be submitted by fax or e-mail per page 12 of the solicitation with hard copy to follow?

Answer. Yes

Question. We assume cost breakdown required is limited to that shown on B-1 price schedule. Is this correct.

Answer. Comply with the cost breakdown structure in accordance with B-1 and the requirements of the Provision L-12 "Business Proposal".

Question. The USG Interiors, Inc. Clean room Wall System is no longer available. Can you provide an alternate system? Can we use the same system that is in rooms 1 - 6? Please advise.

Answer: The specification is changed to include additional requirements for the wall systems and equivalent suppliers of material. See paragraph 3. below. The scheme for Clean Rooms 1-6 is acceptable, however as originally stated in the specification, the panel must be a minimum ½" thick, metal honeycomb core and metal backed, but now may be up to 48" wide.

Question. Are there any percentages for the small business-subcontracting plan or do we name our own?

Answer. The subcontracting plan's goals are based on the offeror's planned subcontracting in support of this requirement.

Question. Is there a General Wage Decision for this project? If applicable, should we use Decision No. DC000003 modification 8 dated 08/10/2001? This is the most recent version that we have for work on the base. If a more current version is available, please provide.

Answer. No. This is a supply contract and therefore a General Wage Decision is not required.

Question. Who is the acceptable manufacturer for Power Conditioning Units? It is listed as "Same As Existing" in section 16462-5 paragraph E.

Answer. Company, Perfect Power Systems (www.PerfectPowerSystems.com) 5701 Smithway St., Commerce, CA. 90040, 800-786-6915. Power Conditioner: 30KVA Three Phase Stabilizer System with Regulation and Conditioning, Model MVT30987321AC-Mon.

2. **Exhibit A, Drawings** are revised to provide two double doors in the east wall of Clean Rooms 7 and 8. The doors will swing into the future Clean Rooms 9 and 10. Steps will be provided at each door. The location of the doors is shown on the sketch provided at <http://heron.nrl.navy.mil/contracts/RFP/03dl08.htm>.

3. **Exhibit B, Specification.** Specification 2.02 Construction and Materials for Wall Systems, Section E. This specification is changed to allow other wall system schemes to be proposed. As originally stated in the specification, the panel must be a minimum ½" thick, metal honeycomb core and metal backed, but now may be up to 48" wide. Systems that may be used if installed in such a way to meet the requirements could be supplied by Plascore, DAW Technologies, PortaFab or equivalent.